

## Fire Performance & Resistance to Premature Collapse No. LELFP0060-00 SALAMANDRE CABLE TRUNKING

Page 1 / 2

We, **Legrand Electric Limited**

have tested representative installed cable management products from the ranges below at the independent test laboratory MPA NRW, Erwitte, Germany to the following standard(s):

**DIN 4102-12** - Fire behaviour of building materials and elements, **Part 12**: Fire resistance of electric cable systems required to maintain circuit integrity – Requirements and testing.

The ratings are dependent on the use of correctly specified & installed cables with intrinsic fire resistance.

**trademark:** *Salamandre Systems*, MSTR (screw fixed)

**designation:** *Cable trunking system*

**Test Summary:** 90 minutes, reaching a temperature of 1000°C.

Product Finish	DIN 4102-12 Fire Rating Classification	Installation Withstand (Resistance to Collapse)
PG – Pre-galvanized	E30	>90mins

**manufactured by:** Legrand Electric Limited  
Great King Street North, Birmingham B19 2LF, United Kingdom.

These provisions are ensured by conformity to the following standards/specifications:

- EN 50085-2-1:2006 +A1:2011 Cable trunking systems and cable ducting systems for electrical installations. Cable trunking systems and cable ducting systems intended for mounting on walls and ceilings
- Section 6.4.2 products classified as non-flame propagating system components

Product(s) listed above are manufactured and supplied in accordance with our Certificates of Registration to both EN ISO 9001:2015 for our QMS and EN 14001:2015 for our EMS.

Every care has been taken in preparing this information and it is given in good faith. It does not, however, constitute a warranty nor imply any guarantee.



Birmingham, 14<sup>th</sup> February 2023  
Place of Issue & Date

.....  
Eur Ing. **J. Wright** B.Eng C.Eng MIET  
Authorised Signatory

**THE GLOBAL SPECIALIST IN ELECTRICAL AND DIGITAL BUILDING INFRASTRUCTURES**  
LEGRAND ELECTRIC LIMITED, Great King Street North, Birmingham, B19 2LF  
Tel : 0370 609 9000 Fax : 0370 608 9004

**Fire Performance & Resistance to Premature Collapse No. LELFP0060-00  
SALAMANDRE CABLE TRUNKING**

Page 2 / 2

**Before and after pictures of Salamandre trunking installed in fire test chamber:**

**Before:**



**After:**



(Note, chains removed prior to photo for clarity)

**THE GLOBAL SPECIALIST IN ELECTRICAL AND DIGITAL BUILDING INFRASTRUCTURES**  
LEGRAND ELECTRIC LIMITED, Great King Street North, Birmingham, B19 2LF  
Tel : 0370 609 9000 Fax : 0370 608 9004